


STYLE NO.	DUTY CYCLE kV	MCOV kVrms	CREEPAGE		LBS	KG	PH TO GRD.		PH TO PH		FIGURE
			IN	MM			IN	MM	IN	MM	
D003SA002ADEE0	3	2.55	6.02	153	2.2	1	3.54	90	4.72	120	1
D003SA002ADEE0	3	2.55	6.02	153	2.2	1	3.54	90	4.72	120	2
D003SA002ADEP0	3	2.55	6.02	153	2.2	1	3.54	90	4.72	120	3
D004SA003ADEE0	4	3.40	6.02	153	2.2	1	3.54	90	4.72	120	1
D006SA005ADEE0	6	5.10	6.02	153	2.2	1	3.54	90	4.72	120	1
D006SA005ADEE0	6	5.10	6.02	153	2.2	1	3.54	90	4.72	120	2
D006SA005ADEP0	6	5.10	6.02	153	2.2	1	3.54	90	4.72	120	3



- E - CABLE TERMINAL WITH M12 STUD, 2 NUTS, LOCKWASHER, FLAT WASHER AND TERMINAL CLAMP.
- P - CABLE TERMINAL WITH INSULATING BRACKET, M12 STUD, 2 NUTS, LOCKWASHER, FLAT WASHER AND TERMINAL CLAMP.
- 0 - CABLE TERMINAL WITH INSULATING BRACKET & DISCONNECTOR WITH M12 STUD, M10 NUT, LOCKWASHER, FLAT WASHER AND TERMINAL CLAMP.
- NAMEPLATE
- 0 - STANDARD ANSI ONLY

HORIZONTAL 3Ø INSTALLATION LAYOUT




FIGURE 1




FIGURE 2




FIGURE 3

FOR TENDER PURPOSES ONLY

01	NOV. 24, 2004	REV. DESCRIPTION & DATE
02	DECEMBER 1, 2006	STYLE D004SA003ADEE0 ADDED
03	JUNE 26, 2012	*S* AND *T* VALUES FOR NEW DISCONNECTOR FROM FIGURE 2-1112 REF. MMS 10.94 REF. 3.37 MMS 3.19 DLM
04	APRIL 14, 2014	CLOUNT HORIZONTAL ADDED TO 3Ø DLM

ALL DIMENSIONS IN INCH (MM) UNLESS NOTED

ABB INC.
Power Products Division
500 Distribution Circle, W. Pittsburg, PA 15066

SCALE: 1:1
SHEET 01 OF 1
PART NUMBER: 4F1002
REV: 4

STANDARD POLIM-D ARRESTER
3-6 KV OUTLINE