



TYPICAL TEST DATA

Dry Type Transformer

GE
Industrial Solutions
Large Power Transformers
41 Woodford Avenue
Plainville, CT 06062
www.geindustrial.com

GE MODEL #: **9T10A1001**

Underwriters' Laboratories Inc. Listed

RATING

KVA	15	Conductor	AL
Frequency	60	Phase	3
Primary Voltage	480D +2, -4 (2.5% taps)	Secondary Voltage	208Y/120
Current Line Primary	18.04	Current Line Secondary	41.64
Frame	UX71A	Insulation System	220C
K Factor	1	Efficiency level	DoE 2016 (10CFR 431)
Temp. Rise (°C)	150	Average Sound Level (dB)	45

LOSS DATA @ 100% LOAD

Core Loss or No Load Loss @ 100% voltage (Watts)	63.0
Impedance Loss or Coil Loss @ Rise + 20C reference (Watts)	<u>471.3</u>
Total Loss @ Rise + 20C reference (Watts)	534.3

DIELECTRIC AND PRODUCTION TESTING

Induce Test @ Twice rated voltage 400 Hz per UL1561 and NEMA ST-20
 Hipot Test for High Voltage winding to Low Voltage and Ground @ 4000 volts 60 Hz 60 Sec
 Hipot Test for Low Voltage winding to High Voltage and Ground @ 2500 volts 60 Hz 60 Sec
 Polarity additive in accordance with UL1561 and NEMA ST-20

EFFICIENCY

DoE 2016 (10CFR 431) Efficiency Level calculated per NEMA TP-1

Load (%)	Efficiency (%)
16	97.10
25	97.81
35	97.89
50	98.09
75	97.82
100	97.42

IMPEDANCE

Impedance at reference temperature of Rise + 20C (Calculated).

%R	3.1
%X	1.9
%Z	3.7
X/R Ratio	0.6

REGULATION

Regulation at reference temperature of Rise + 20C (Calculated).

PF	Regulation (%)
1.0	3.2
0.9	3.7
0.8	3.7

REFERENCE VALUES:

Inrush Current (Calculated).	t= 8.33ms
I _{max} (RMS) =	278.41