



# 300-Line

## Lighting Contactors CR360L

**Caution:** Before installing in a nuclear application, determine that the product is intended for such use.

**Warning:** Disconnect power before installing or servicing.

### Ratings Open And Enclosed

Continuous—300 Amperes Per Pole Maximum

Lighting Load	Maximum AC Volts	
	Line	Load
Tungsten Lamp	480	480
Ballast	600	600

### Features

- Horizontal straight-line motion makes contactor compact, easy to maintain.
- Strongbox coil.
- Straight-through wiring.
- Large combination knockouts.
- Oversized power terminals will accommodate up to #500 MCM wire.

### Installation

Before connecting contactor to power supply:

1. Remove all packing.
2. Clean magnet mating surfaces.
3. Operate movable magnet and operating arm by pressing on the nameplate to assure free movement.
4. Mount contactor on a sturdy vertical support.
5. Be certain wiring connections are tight
6. Give installation a final check for conformance with codes, branch circuit protection and remove any foreign material from enclosure. Also check to see that no tools have been left in panel during installation. Review diagrams for intended operation and function.
7. Before energizing, make final check to see that all power lines and terminals are free of metal or pieces of wire that could cause shorts to other parts or ground and additionally that wiring and equipment on load side of contactor is free from grounds and shorts. An ohmmeter or other means, as appropriate, is recommended.



Disconnect All Power  
Before Servicing.

Read Instructions  
For This Equipment.

### Maintenance

1. Keep magnet mating surfaces free of any accumulated dirt or dust.
2. **DO NOT OIL OR GREASE** the magnet mating surfaces.

3. The silver-cadmium oxide contacts need only be replaced when nearly all tip material is gone and contact tip support material is exposed. **DO NOT FILE** the contacts. Filing or otherwise dressing the contacts results in lost tip material and reduces contactor life.




Figure 1. 300 ampere lighting contactor, CR360L.

### Removal Of Coil

1. Loosen 4 coil retainer screws (Figure 1). Press against coil and pull up and out on coil retainers (Figure 1).
2. Draw movable portion of magnet assembly from the contactor.
3. Pull one end of spring clip forward and slide out of slot.
4. Coil can then be lifted out.
5. Replace coil and reassemble, reversing the procedure.

### Removal Of Contacts

1. Remove coil as described under *Removal Of Coil*.
2. Remove complete magnet assembly by grasping magnet retaining straps and pull entire assembly from the contactor.
3. With the magnet assembly resting on its side, remove the movable tip carrier by sliding it out the back of the assembly.
4. Depress movable tip and spring and slide the movable tip out of the tip carrier.
5. While holding the spring and spring guide depressed, slide the new tip into position.
6. Remove the two screws holding the stationary contact to base support and remove stationary contact.
7. Reassemble by reversing the above procedure.

*Note:* Do not attempt to remove or replace arc traps in arc chute cover.

When reassembling, note that the arc chute cover will only fit one way and is marked *TOP* in upper right hand corner. Magnet and movable arm will fit either way but will be quieter if reassembled the same way they were taken apart.

### "Standard" Short Circuit Ratings

Suitable For Use On A Circuit Capable Of Delivering Not More Than 18,000 RMS Symmetrical Amperes, 600 Volts Maximum. Use Fuses Rated 1600 Amperes Maximum, or Circuit Breakers Rated 1600 Amperes Maximum.

### "High-Available" Short Circuit Ratings

Suitable For Use On A Circuit Capable Of Delivering Not More Than (a) RMS Symmetrical Amperes, (b) Volts Maximum, When Protected by (e) Type (f) Circuit Breakers, Rated (g) Amperes Maximum.

Catalog Number	Max Amperes	Short Circuit Rating		Maximum Breaker Size		
		RMS Sym Amperes (a)	Volts Max (b)	Make (e)	Model (f)	Max. Size (g)
CR360L7	300	65,000	480	GE	SGL	600
CR360L7	300	35,000	480	GE	SGH	600
CR360L7	300	65,000	480	GE	SKL	1200
CR360L7	300	50,000	480	GE	SKH	1200

### Principal Renewal Parts

Coil for 2- and 3-pole forms. Order as Catalog Number 55-530249G plus group number from Coil Data Table.

Coil for 4 or 5 pole forms. Order as Catalog Number 55-501493G plus group number from Coil Data Table.

*EXAMPLE: For 230 V, 60 Hz coil, 2- and 3-pole, order Catalog Number 55-530249G003.*

### Coil Data Table

Frequency	115V	200/208V	230V	480V	575V	600V
60 Hertz	002	023	003	004	005	006
Frequency	110V	220V	380V	440V	550V	600V
50 Hertz	007	008	064	009	010	011

Use 022 for 120V, 60 Hz/110V, 50 Hz coil.

### Contacts

Complete set of stationary and movable contacts, springs, and screws:  
For 3 poles ..... Catalog Number 55-154607G041

### Accessory Kits

Pushbutton, ON-OFF ..... CR305X520C  
Selector Switch, ON-OFF ..... CR305X530D  
Indicating Light ..... CR305X550B

### Auxiliary Contact Kit Identification

Catalog Number	Description	Contact Configuration
CR305X500A	Basic Block	1 NO
CR305X500B	Basic Block	1 NC
CR305X500C	Basic Block	1 NO-1 NC
CR305X100D	Adder Block	1 NO
CR305X100E	Adder Block	1 NC

Note: One or two adder blocks may be added to each basic block.

These instructions do not purport to cover all details or variations in equipment nor to provide for every possible contingency to be met in connection with installation, operation or maintenance. Should further information be desired or should particular problems arise which are not covered sufficiently for the Purchaser's purposes, the matter should be referred to the nearest General Electric Sales Office.



**GE Industrial Systems**