



**Attach on your Circuit Breaker Panel
Box or in an easily visible location.**

GFCI GROUND FAULT CIRCUIT INTERRUPTER BREAKER

TEST INSTRUCTIONS and RECORD CHART

User's General Information

When properly installed, each GFCI circuit breaker (red TEST button) or ground fault equipment protection circuit breaker (yellow TEST button) in this panel provides reliable overload and short circuit protection PLUS protection from ground fault that might result from contact with a "HOT" load wire and ground.

IMPORTANT NOTE - These circuit breakers will NOT reduce shock hazard if contact is made between a "HOT" Load Wire and Neutral Wire or 2 "HOT" Load Wires.

FOR YOUR PROTECTION, PROPER INSTALLATION AND REGULAR TESTING IS IMPORTANT. SEE OTHER SIDE FOR INSTRUCTIONS.

Each GFCI circuit breaker is calibrated to trip with a ground current of at 5 milliamperes or more. Since most persons can feel as little as 2 milliamperes, a distinct shock may be felt if the need for personnel protection exists. However, the shock should be of such short duration that the effects will be reduced to less than the normally dangerous level. However, persons with acute heart problems or other conditions that can make a person particularly susceptible to electric shock, may still be seriously injured. 30 milliampere ground fault equipment protection circuit breakers (yellow TEST button) are *NOT* intended, and are *NOT* suitable, for ground fault protection of personnel coming in contact with electrical parts. Use 5 milliampere GFCI circuit breakers for this application.

While the GFCI circuit breaker affords a high degree of protection, there is no substitute for the knowledge that electricity can be dangerous when carelessly handled or used without reasonable caution.

WARNING

**A circuit breaker provides protection only to the circuit to which it
is connected. It does NOT provide protection to any other circuit.**



GE Industrial Systems

General Electric Company
41 Woodford Ave, Plainville, CT 06062
GEZ-5802 R2 1201 © 2001 General Electric Company

