



- NOTES:**
1. OPERATOR INTERFACE PANEL.
 2. MAIN INPUT CIRCUIT BREAKER.
 3. 225A SECONDARY MAIN CIRCUIT BREAKER.
 4. (42) POLE DISTRIBUTION PANELBOARDS.
 5. CT STRIP FOR BCMS (OPTIONAL).
 6. RECOMMEND A MINIMUM OF 30" IN REAR OR SIDE OF UNIT FOR MAINTENANCE.
 7. MINIMUM OF 18" CLEARANCE FOR DOOR SWING.
 8. RECOMMEND 6" CLEARANCE BETWEEN VENTILATED SIDES AND WALL FOR PROPER COOLING.
 9. BCMS CIRCUIT BOARD (OPTIONAL).

FRONT VIEW
(DOOR AND COVERS REMOVED)

SIDE VIEW
(DOOR AND COVERS REMOVED)

THIS DRAWING CONTAINS
CONFIDENTIAL & PROPRIETARY
INFORMATION AND SHALL NOT
BE DISCLOSED OR COPIED
WITHOUT THE EXPRESSED
WRITTEN PERMISSION OF
GENERAL ELECTRIC CO.

TITLE GE ZENITH SERIES MDU, CLASSIC DESIGN 50-150kva, 1 OR 2 PANELBOARDS W/ BCMS OPTION		DWG. NUMBER DWG11001-GE		REVISION A2	
DRAWN BY RAE	CHECKED BY DAS	DATE 09-08-09	DATE 01-02-13	GE Critical Power	

