


- NOTES:**
1. OPERATOR INTERFACE PANEL.
 2. MAIN INPUT CIRCUIT BREAKER.
 3. 225A SECONDARY MAIN CIRCUIT BREAKER.
 4. (42) POLE DISTRIBUTION PANELBOARDS.
 5. RECOMMEND A MINIMUM OF 30" IN REAR OR SIDE OF UNIT FOR MAINTENANCE.
 6. MINIMUM OF 18" CLEARANCE FOR DOOR SWING IN FRONT.
 7. MINIMUM OF 32" CLEARANCE FOR DOOR SWING ON SIDE.
 8. RECOMMEND 6" CLEARANCE BETWEEN VENTILATED SIDES AND WALL FOR PROPER COOLING.

THIS DRAWING CONTAINS
 CONFIDENTIAL & PROPRIETARY
 INFORMATION AND SHALL NOT
 BE DISCLOSED OR COPIED
 WITHOUT THE EXPRESSED,
 WRITTEN PERMISSION OF
 GENERAL ELECTRIC CO.

TITLE GE ZENITH SERIES MDU, CLASSIC DESIGN 50-150kva , RH SF SIDECAR 4 PANELBOARDS		DWG. NUMBER DMG11011-GE		REVISION A2	
DRAWN BY RAE		CHECKED BY KH		 GE Critical Power	
DATE 09-10-09		DATE 12-31-12			