



- NOTES:**
1. OPERATOR INTERFACE PANEL.
  2. MAIN INPUT CIRCUIT BREAKER.
  3. 225A SECONDARY MAIN CIRCUIT BREAKER.
  4. (42) POLE DISTRIBUTION PANELBOARDS.
  5. CT STRIP FOR BCMS (OPTIONAL).
  6. RECOMMEND A MINIMUM OF 30" IN REAR OR SIDE OF UNIT FOR MAINTENANCE.
  7. MINIMUM OF 18" CLEARANCE FOR DOOR SWING.
  8. RECOMMEND 6" CLEARANCE BETWEEN VENTILATED SIDES AND WALL FOR PROPER COOLING.
  9. BCMS CIRCUIT BOARD (OPTIONAL).

THIS DRAWING CONTAINS  
 CONFIDENTIAL & PROPRIETARY  
 INFORMATION AND SHALL NOT  
 BE DISCLOSED OR COPIED  
 WITHOUT THE EXPRESSED,  
 WRITTEN PERMISSION OF  
 GENERAL ELECTRIC CO.

|                   |  |                                      |  |
|-------------------|--|--------------------------------------|--|
| TITLE             |  | GE ZENITH SERIES MDU, CLASSIC DESIGN |  |
| DWG. NUMBER       |  | (2) PANELBOARDS W/ BCMS OPTION       |  |
| DRAWN BY          |  | REVISION                             |  |
| DATE              |  | DATE                                 |  |
| CHECKED BY        |  | DATE                                 |  |
| GE Critical Power |  | GE                                   |  |